



**GREEN SPAN PROFILES®**  
INSULATED PANEL TECHNOLOGIES

---

---

## ARCHITECTURAL TECHNICAL BULLETIN

---

---

**PRODUCT:**

IWP Series – Insulated Metal Wall Panel  
Component: Polyisocyanurate (PIR) insulating foam core  
System: Rubitherm WR 40618 / Rubinate 1850  
Blowing Agent: Non-ozone depleting Pentane (C<sub>5</sub>H<sub>10</sub>)

**TEST PROTOCOL:**

NFPA 285-12, Standard Fire Test Method for Evaluation of Fire Propagation Characteristics of Exterior Non-Load-Bearing Wall Assemblies Containing Combustible Components

**TEST LOCATION:**

INTERTEK, 16015 Shady Falls Road, Elmendorf, TX 78112

**REPORT NUMBER:**

103176855SAT-003

**RESULTS:**

The assembly described and tested herein **did** meet the Conditions of Acceptance for NFPA 285. Thus satisfying Chapter 26, Section 2603.5.5 of the International Building Code, 2015.

---

---

**ATB-0007**

**APRIL 30, 2018**

*SUBJECT TO CHANGE WITHOUT NOTICE – Please visit our website for the most current information*

Green-Span Profiles, LP  
21200 FM 362 | Waller, TX 77484  
(281) 807-7400 | [www.greenspanprofiles.com](http://www.greenspanprofiles.com)