



ENGINEERING TECHNICAL BULLETIN

PRODUCT:

IWP Series – Insulated Metal Wall Panel
IRP Series – Insulated Metal Roof Panel
Component: Polyisocyanurate (PIR) insulating foam core
System: Rubitherm WR 40618 / Rubinate 1850
Blowing Agent: Non-ozone depleting Pentane (C₅H₁₀)

TEST PROTOCOL:

ASTM D1623-09 Tensile and Tensile Adhesion Properties of Rigid Cellular Plastics

TEST LOCATION:

Huntsman Advanced Technology Center, 8600 Gosling Road, The Woodlands, TX 77381

REPORT NUMBER:

HTR-061912

RESULTS:

Tensile Strength	21-psi
------------------	--------

ETB-0006

MARCH 6, 2012

SUBJECT TO CHANGE WITHOUT NOTICE – Please visit our website for the most current information